

ARKANSAS DEPARTMENT OF TRANSPORTATION  
EQUIPMENT AND PROCUREMENT OFFICE  
LITTLE ROCK, ARKANSAS

December 13, 2018

NOTICE TO BIDDERS  
ADDENDUM

Bid No. M-19-021P

Construction of Grounds Crew Building/Shop  
Little Rock, AR

OPENING DATE: December 18, 2018

**Revisions and Clarifications to the Specifications:**

**Plan revisions include:**

Addition of EF-1 to panel schedule and homerun designation.

1. Circuit A21/Single Pole 30 amp Breaker.
2. Sheet M1.1, add EF2 to Mechanical Equipment Schedule. EF2 Shall be Broan, Model QTXE080 w/backdraft damper.

Additional emergency lighting and panel schedule designation.


3. Add Exit/Emergency light at both exterior walk doors.
4. Add additional emergency lighting as required by code.

In reference to Sheet A1.1: Door schedule, Door 1 shall have 1" insulating glass in lieu of 1/4" tempered glass.

**Electrical Service Clarification:**

New Electric Service must be installed from Entergy pole as shown on Sheet C1.1.

ALL OTHER SPECIFICATIONS SHALL REMAIN THE SAME.



Danny Keene  
Division Head  
Equipment and Procurement